

# AMP DISPLAY INC.

### **SPECIFICATIONS**

# 7.0-in COLOR TFT MODULE W/O TOUCH

CUSTOMER:						
CUSTOMER PART NO.						
AMP DISPLAY PART NO.	A M 8 0 0 4 8 0 S T M Q W - B 0					
APPROVED BY:						
DATE:						
APPROVED FOR SPECIFICATIONS APPROVED FOR SPECIFICATION AND PROTOTYPES						

# **AMP DISPLAY INC**

9856 SIXTH STREET RANCHO CUCAMONGA CA 91730 TEL: 909-980-13410 FAX: 909-980-1419 WWW.AMPDISPLAY.COM

### **RECORD OF REVISION**

Revision Date	Page	Contents	Editor
2009/09/03		New Release	Emil
2009/09/09		Issued the official part No. to AM-800480STMQW-B0.	Emil
2009/09/09	6	Revised the Interface Definition.	Emil
2009/09/25	19,20	Update the Mechanical drawing.	Emil
2009/09/25	5	Update the electrical characteristic.	Emil
2009/11/17	5	Added the LED life time.	Eric
2009/11/18	19	Update the Mechanical drawing.	Eric

#### 1. INTRODUCTION

Ampire Display Module is a color active matrix TFT-LCD that uses amorphous silicon TFT as a switching device . This model is composed of a TFT-LCD panel and timing controller. This TFT-LCD has a high resolution ( $800(R.G.B) \times 480$ ) and can display up to 262,144 colors .

#### 1-1. Features

• 7" WVGA (16:9 diagonal) configuration

• Input interface voltage : 3.3V

• Data enable mode

#### 1-2. Applications

Portable TV

• Car user DVD

Industrial application

• HMI (Human machine interface)


#### 2. PHYSICAL SPECIFICATIONS

Item	Specifications	unit
Display resolution(dot)	800RGB (W) x 480(H)	dots
Active area	152.4 (W) x 91.44 (H)	mm
Pixel pitch	0.1905 (W) x 0.1905 (H)	mm
Color configuration	R.G.B Vertical stripe	
Overall dimension	165.0(W)x104.44(H)x9.16 max(T)	mm
Weight	135	g
Brightness	350 nit(typ)	cd/m <sup>2</sup>
Contrast ratio	400 : 1	
Backlight unit	LED	
Display color	262,144	colors

### 3. ABSOLUTE MAX. RATINGS

ITEM	SYMBOL	MIN	MAX	UNIT
Power Supply Voltage for LCD	Vcc	-0.5	6.0	V
Signal input voltage	DCLK DE R0~R5 G0~G5 B0~b5	-0.5	VCC+0.5	٧
Operation Temperature	Тор	-20	70	$^{\circ}\!\mathbb{C}$
Storage Temperature	Tstg	-30	80	$^{\circ}\!\mathbb{C}$

The following values are maximum operation conditions , If exceeded , it may cause faulty operation or damage  $\,$ 




#### 4. ELECTRICAL CHARACTERISTICS

### 4-1 TFT LCD Module voltage


ITEM		SYMBOL	MIN	TYP	MAX	UNIT	CONDITION
Power S For LCD	upply Voltage	Vcc	3.0	3.3	3.6	V	
Power S For LCD	upply Current	Icc	-	150	250	mA	VCC=3.3V
Power S For LED	upply Voltage	VLED	4.5	5.0	5.5	V	
Power S	upply Current	ILED	-	380	ı	mA	VLED=5V VADJ=3.3V (duty 100%)
For LED			-	650	-	ША	VLED=3.3V VADJ=3.3V (duty 100%)
LED Bac	klight Voltage	$V_{BL}$	-	9.9	-	V	IBL=160mA
LED Bac	LED Backlight Current		-	160	1	mA	VLED=5V VADJ=3.3V (duty 100%)
ADJ Inpu	ut Voltage	$V_{ADJ}$	-	3.3	5	V	duty=100%
LED Life time		-	10k	20k	-	Hrs	
	Input Voltage	V <sub>IN</sub>	0	-	Vcc	V	
Logic Input	Threshold Voltage(High)	$V_{TH}$	3.0	-	Vcc	V	
Voltage	Threshold Voltage(Low)	V <sub>TL</sub>	GND	ı	0.5	V	

Note 1:

- VCC -dip codition: 1) When 2.7 V≤VCC < 3.0V , td≤10ms.
  - 2) VCC>3.0V , VCC-dip condition should be same as VCC-turn-on condition.



Note 2:The constant current source is needed for white LED back-light driving. When LCM is operated over  $60^{\circ}\text{C}$  ambient temperature, the  $I_{BL}$  of the LED back-light should be adjusted to 145mA max




**LED Light Bar Circuit** 

## **5. INTERFACE**

1         LGND         LED Driver Ground           2         LGND         LED Driver Ground           3         ADJ         Adjust for LED Brightness           4         VLED         Power supply for LED (5V)           5         VLED         Power supply for LED (5V)           6         VLED         Power supply for LCD (3.3V)           8         VCC         Power supply for LCD (3.3V)           9         DE         Data Enable Timing Signal           10         SK/XL         For Touch panel used; (Keep NC).           11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB         Blue data (MSB)           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data (LSB)           20         GND         Ground           21         G5         Green data           23         G3         Green data           24         GND         Ground           25         G2	Pin no	Symbol	Function
2		•	
ADJ	-		
4         VLED         Power supply for LED (5V)           5         VLED         Power supply for LED (5V)           6         VLED         Power supply for LED (5V)           7         VCC         Power supply for LCD (3.3V)           8         VCC         Power supply for LCD (3.3V)           9         DE         Data Enable Timing Signal           10         SK/XL           11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1			
5         VLED         Power supply for LED (5V)           6         VLED         Power supply for LED (5V)           7         VCC         Power supply for LCD (3.3V)           8         VCC         Power supply for LCD (3.3V)           9         DE         Data Enable Timing Signal           10         SK/XL           11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           28         GND         Grou			,
6 VLED Power supply for LED (5V) 7 VCC Power supply for LCD (3.3V) 8 VCC Power supply for LCD (3.3V) 9 DE Data Enable Timing Signal 10 SK/XL 11 DO/XR For Touch panel used; (Keep NC). 12 DI/YB 13 B5 Blue data (MSB) 14 B4 Blue data 15 B3 Blue data 16 GND Ground 17 B2 Blue data 18 B1 Blue data 19 B0 Blue data (LSB) 20 GND Ground 21 G5 Green data (MSB) 22 G4 Green data 23 G3 Green data 24 GND Ground 25 G2 Green data 26 G1 Green data 27 G0 Green data (LSB) 28 GND Ground 29 R5 Red data (MSB) 30 R4 Red data 31 R3 Red data 32 GND Ground 33 R2 Red data 34 R1 Red data 35 R0 Red data (LSB) 36 TPCS/YU 37 IRQ  For Touch panel used; (Keep NC).			
7         VCC         Power supply for LCD (3.3V)           8         VCC         Power supply for LCD (3.3V)           9         DE         Data Enable Timing Signal           10         SKXL           11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data			
8         VCC         Power supply for LCD (3.3V)           9         DE         Data Enable Timing Signal           10         SK/XL           11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31			, , ,
9 DE Data Enable Timing Signal 10 SK/XL 11 DO/XR For Touch panel used; (Keep NC). 12 DI/YB 13 B5 Blue data (MSB) 14 B4 Blue data 15 B3 Blue data 16 GND Ground 17 B2 Blue data 18 B1 Blue data 19 B0 Blue data (LSB) 20 GND Ground 21 G5 Green data (LSB) 22 G4 Green data 23 G3 Green data 24 GND Ground 25 G2 Green data 26 G1 Green data 27 G0 Green data (LSB) 28 GND Ground 29 R5 Red data (MSB) 30 R4 Red data 31 R3 Red data 33 R2 Red data 34 R1 Red data 35 R0 Red data (LSB) For Touch panel used; (Keep NC).			
10			
11         DO/XR         For Touch panel used; (Keep NC).           12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34			Data Effable fiffling Signal
12         DI/YB           13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         TOuch panel used; (Keep NC).			For Touch monel woods (Keen NO)
13         B5         Blue data (MSB)           14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         TOuch panel used; (Keep NC).			For Touch panel used; (Keep NC).
14         B4         Blue data           15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			Division data (MCD)
15         B3         Blue data           16         GND         Ground           17         B2         Blue data           18         B1         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         TOLCh panel used; (Keep NC).			
16         GND         Ground           17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
17         B2         Blue data           18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
18         B1         Blue data           19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
19         B0         Blue data (LSB)           20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
20         GND         Ground           21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         TPCS/YU           37         IRQ         For Touch panel used; (Keep NC).			
21         G5         Green data (MSB)           22         G4         Green data           23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           For Touch panel used; (Keep NC).         For Touch panel used; (Keep NC).			· , ,
22       G4       Green data         23       G3       Green data         24       GND       Ground         25       G2       Green data         26       G1       Green data (LSB)         28       GND       Ground         29       R5       Red data (MSB)         30       R4       Red data         31       R3       Red data         32       GND       Ground         33       R2       Red data         34       R1       Red data         35       R0       Red data (LSB)         36       TPCS/YU       For Touch panel used; (Keep NC).			
23         G3         Green data           24         GND         Ground           25         G2         Green data           26         G1         Green data (LSB)           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			` '
24         GND         Ground           25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
25         G2         Green data           26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
26         G1         Green data           27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
27         G0         Green data (LSB)           28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
28         GND         Ground           29         R5         Red data (MSB)           30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
29       R5       Red data (MSB)         30       R4       Red data         31       R3       Red data         32       GND       Ground         33       R2       Red data         34       R1       Red data         35       R0       Red data (LSB)         36       TPCS/YU         37       IRQ         For Touch panel used; (Keep NC).			
30         R4         Red data           31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
31         R3         Red data           32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).	29		· · ·
32         GND         Ground           33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).			
33         R2         Red data           34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).           37         IRQ			
34         R1         Red data           35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).           37         IRQ	32	GND	Ground
35         R0         Red data (LSB)           36         TPCS/YU         For Touch panel used; (Keep NC).           37         IRQ			Red data
36 TPCS/YU For Touch panel used; (Keep NC).	34	R1	Red data
37 IRQ For Touch panel used; (Keep NC).	35	R0	Red data (LSB)
37 IRQ	36	TPCS/YU	For Touch nanel used: (Keen NC)
	37	IRQ	i or rough parier used, (Neep 140).
38 DCLK Data Clock	38	DCLK	Data Clock
39 GND Ground	39	GND	Ground
40 GND Ground	40	GND	Ground

NOTE: Pin3: ADJ is PWM signal input. It is for brightness control.

ITEM	SYMBOL	MIN	TYP	MAX	UNIT
ADJ signal frequency	fрwм	100		1K	Hz
ADJ signal logic level High	VIH	2V		VLED (5.0V)	V
ADJ signal logic level Low	VIL	0		0.5	V




## **6. OPTICAL CHARACTERISTICS**

Item		Symbol	Condition	Min.	Тур.	Max.	Unit	Note
	Front	θf		50	60			
Viewing	Back	θЬ	CD > 40	60	70		مامد	(4)(2)(2)
Angle	Left	θΙ	CR≧10	60	70		deg.	(1)(2)(3)
	Right	θr		60	70			
Contrast ratio		CR	Θ=Φ=0°	250	400			(1)(3)
Dognanaa Tin	20	T <sub>r</sub>			5	10	ms	(1)(4)
Response Tin	iie	$T_f$			11	16	ms	(1)(4)
	White	Wx	Θ=Φ=0°	0.249	0.299	0.349		
		Wy		0.278	0.328	0.378		
	Red	Rx		0.522	0.572	0.622		
Color		Ry		0.308	0.358	0.408		(1)
chromaticity	Green	Gx		0291	0.341	0.391		(1)
	Green	Gy		0.534	0.584	0.634		
	Blue	Вх		0.082	0.132	0.182		
	Blue	Ву		0.083	0.133	0.183		
Luminance		L	Θ=Φ=0°	300	350		cd/m²	(1)(5)
Luminance Uniformity		ΔL	Θ=Φ=0°	70			%	(1)(5)(6)

Note 1: Ta=25°C. To be measured on the center area of panel after 10 minutes operation.

Note 2: Definition of Viewing Angle




#### Note 3: Definition of contrast ratio:

Contrast ratio is calculated with the following formula.


Contrast ratio(CR)= Photo detector output when LCD is at "White" state
Photo detector Output when LCD is at "Black" state

#### Note 4: Definition of response time:

The output signals of photo detector are measured when the input signals are changed from "black" to "white" (falling time) and from "white" to "black" (rising time) respectively. The response time is defined as the time interval between the 10% and 90% of amplitudes. Refer to figure as below.



Note 5: Luminance is measured at point 5 of the display.





Note 6: Definition of Luminance Uniformity

 $\Delta L = [L(min.) \text{ of 9 points } / L(max.) \text{ of 9 points}] X 100\%$ 


# 7. INPUT SIGNAL ( DE ONLY MODE )

Parameter	Symbol		Unit		
Farameter	Syllibol	Min.	Тур.	Max.	H
Data setup time	Tdsu	6	-	- <	ns
Data hold time	Tdhd	6	-	-	Tcph
DE setup time	Tesu	6	-	7	Tcph
CLK frequency	<b>F</b> срн		33.26	\ \ \	MHz
CLK period	Тсрн		30.06	1	ns
CLK pulse duty	Тсwн	40	50	60	%
DE period	TDEH+TDEL	1000	1056	1200	Тсрн
DE pulse width	TDEH	-	800	-	Тсрн
DE frame blanking	TDEB	10	45	110	TDEH+TDEL
DE frame width	TDE	<u> </u>	480	-	TDEH+TDEL





## **Power Sequence**



Parameter		Unit			
Farameter	Min.	Тур.	Max.	Ullit	
T1	1		2	ms	
T2	0	60		ms	
Т3	200			ms	
T4	200			ms	
T5	1			ms	
T6	1000			ms	

#### 9. QUALITY AND RELIABILITY

#### 9.1 TEST CONDITIONS

Tests should be conducted under the following conditions:

Ambient temperature :  $25 \pm 5^{\circ}$ C Humidity :  $60 \pm 25\%$  RH.

#### 9.2 SAMPLING PLAN


Sampling method shall be in accordance with MIL-STD-105E , level II, normal single sampling plan .

#### 9.3 ACCEPTABLE QUALITY LEVEL

A major defect is defined as one that could cause failure to or materially reduce the usability of the unit for its intended purpose. A minor defect is one that does not materially reduce the usability of the unit for its intended purpose or is an infringement from established standards and has no significant bearing on its effective use or operation.

#### 9.4 APPEARANCE

An appearance test should be conducted by human sight at approximately 30 cm distance from the LCD module under florescent light. The inspection area of LCD panel shall be within the range of following limits.




## 9.5 Incoming Inspection Standard


Defect Type			Limit						Note
				φ<0.15mm					
		Spot	0.1	5mm≦	≨φ≦0	.5mm	N	l≦4	(1)
					mm<	<u> </u>	1	<b>1=</b> 0	
Visual		Fiber	0	.1mm< ≧	:W≦0 ≦1.5mr		N	l≦4	(1)
Defect	Internal		1.0	mm<	W, 1.5	mm<	L N	<b>V=</b> 0	
20.000		Dolorizor		$\varphi < 0$	).15mr	n	Ig	nore	
		Polarizer Bubble	0.1	5mm ≦	≦φ≦0	.5mm	N	l≦4	(1)
		5455.0		0.5	mm<	φ	1	<b>V=</b> 0	
		Mura	It' OK	It' OK if mura is slight visible thro					
	Bright Dot		A Grade B G			3 Grad	е		
			C Area	O Area	Total	C Area	O Area	Total	(3)
				N≦2	N≦2	N≦2	N≦3	N≦5	(2)
	Dark Dot		N≦2	N≦4	N≦4	N≦3	N≦5	N≦8	
Electrical Defect	Т	Total Dot		N≦4		N≦5	N≦6	N≦8	(2)
	Two Adjacent Dot		N≦0	N≦1 pair	N≦1 pair	N≦1 pair	N≦1 pair	N≦1 pair	(4)
	Three or	More Adjacent Dot	Not Allowed						
	Lir	ne Defect			Not A	llowed			

- (1) One pixel consists of 3 sub-pixels, including R,G, and B dot.(Sub-pixel = Dot)
- (2) LITTLE BRIGHT DOT acceptable under 6% ND-Filter

[Note1] W: Width[mm], L: Length[mm], N: Number,  $\phi$ : Average Diameter



[Note2] Bright dot is defined through 6% transmission ND Filter as following.




C Area: Center of display area

# C Area: Outer of display area

### [Note4]

Judge defect dot and adjacent dot as following. Allow below (as A, B, C and D status) adjacent defect dots, including bright and dart adjacent dot. And they will be counted 2 defect dots in total quantity.



- (1) The defects that are not defined above and considered to be problem shall be reviewed and discussed by both parties.
- (2) Defects on the Black Matrix, out of Display area, are not considered as a defect or counted.

### 9.6 RELIABILITY TEST CONDITIONS

Test Item	Test Conditions	Note			
High Temperature Operation	70±3°C , t=96 hrs				
Low Temperature Operation	-20±3°C , t=96 hrs				
High Temperature Storage	80±3°C , t=96 hrs	1,2			
Low Temperature Storage	-30±3°C , t=96 hrs	1,2			
Thermal Shock Test	-30°C ~ 25°C ~ 80°C 30 m in. 5 min. 30 min. (1 cycle ) Total 5 cycle	1,2			
Humidity Test	40 °C, Humidity 90%, 96 hrs	1,2			
Vibration Test (Packing)	Sweep frequency: 10 ~ 55 ~ 10 Hz/1min Amplitude: 0.75mm Test direction: X.Y.Z/3 axis Duration: 30min/each axis				

Note 1 : Condensation of water is not permitted on the module.

Note 2 : The module should be inspected after 1 hour storage in normal conditions

(15-35°C, 45-65%RH).

Definitions of life end point :

- Current drain should be smaller than the specific value.
- Function of the module should be maintained.
- Appearance and display quality should not have degraded noticeably.
- Contrast ratio should be greater than 50% of the initial value.

#### 10. USE PRECAUTIONS

#### 10-1 Handling precautions

- (1) The polarizing plate may break easily so be careful when handling it. Do not touch, press or rub it with a hard-material tool like tweezers.
- (2) Do not touch the polarizing plate surface with bare hands so as not to make it dirty. If the surface or other related part of the polarizing plate is dirty, soak a soft cotton cloth or chamois leather in benzine and wipe off with it. Do not use chemical liquids such as acetone, toluene and isopropyl alcohol. Failure to do so may bring chemical reaction phenomena and deteriorations.
- (3) Remove any spit or water immediately. If it is left for hours, the suffered part may deform or decolorize.
- (1) If the LCD element breaks and any LC stuff leaks, do not suck or lick it. Also if LC stuff is stuck on your skin or clothing, wash thoroughly with soap and water immediately.

#### 10-2 Installing precautions

- (1) The PCB has many ICs that may be damaged easily by static electricity. To prevent breaking by static electricity from the human body and clothing, earth the human body properly using the high resistance and discharge static electricity during the operation. In this case, however, the resistance value should be approx.  $1M\Omega$  and the resistance should be placed near the human body rather than the ground surface. When the indoor space is dry, static electricity may occur easily so be careful. We recommend the indoor space should be kept with humidity of 60% or more. When a soldering iron or other similar tool is used for assembly, be sure to earth it.
- (2) When installing the module and ICs, do not bend or twist them. Failure to do so may crack LC element and cause circuit failure.
- (3) To protect LC element, especially polarizing plate, use a transparent protective plate (e.g., acrylic plate, glass etc) for the product case.
- (4) Do not use an adhesive like a both-side adhesive tape to make LCD surface (polarizing plate) and product case stick together. Failure to do so may cause the polarizing plate to peel off

#### 10-3 Storage precautions

- (1) Avoid a high temperature and humidity area. Keep the temperature between 0°C and 35°C and also the humidity under 60%.
- (2) Choose the dark spaces where the product is not exposed to direct sunlight or fluorescent light.
- (3) Store the products as they are put in the boxes provided from us or in the same conditions as we recommend.

#### 10-4 Operating precautions

- (1) Do not boost the applied drive voltage abnormally. Failure to do so may break ICs. When applying power voltage, check the electrical features beforehand and be careful. Always turn off the power to the LC module controller before removing or inserting the LC module input connector. If the input connector is removed or inserted while the power is turned on, the LC module internal circuit may break.
- (2) The display response may be late if the operating temperature is under the normal standard, and the display may be out of order if it is above the normal standard. But this is not a failure; this will be restored if it is within the normal standard.
- (3) The LCD contrast varies depending on the visual angle, ambient temperature, power voltage etc. Obtain the optimum contrast by adjusting the LC dive voltage.
- (4) When carrying out the test, do not take the module out of the low-temperature space suddenly. Failure to do so will cause the module condensing, leading to malfunctions.
- (5) Make certain that each signal noise level is within the standard (L level: 0.2Vdd or less and H level: 0.8Vdd or more) even if the module has functioned properly. If it is beyond the standard, the module may often malfunction. In addition, always connect the module when making noise level measurements.
- (6) The CMOS ICs are incorporated in the module and the pull-up and pull-down function is not adopted for the input so avoid putting the input signal open while the power is ON.
- (7) The characteristic of the semiconductor element changes when it is exposed to light emissions, therefore ICs on the LCD may malfunction if they receive light emissions. To prevent these malfunctions, design and assemble ICs so that they are shielded from light emissions.
- (8) Crosstalk occurs because of characteristics of the LCD. In general, crosstalk occurs when the regularized display is maintained. Also, crosstalk is affected by the LC drive voltage. Design the contents of the display, considering crosstalk.

#### 10-5 Other

- (1) Do not disassemble or take the LC module into pieces. The LC modules once disassembled or taken into pieces are not the guarantee articles.
- (2) The residual image may exist if the same display pattern is shown for hours. This residual image, however, disappears when another display pattern is shown or the drive is interrupted and left for a while. But this is not a problem on reliability.
- (3) AMIPRE will provide one year warrantee for all products and three months warrantee for all repairing products..

#### 11. OUTLINE DIMENSION

